



**STEAM PRV STATION DETAIL**  
SCALE: NONE

**NOTES FOR DESIGNER:** (DO NOT INCLUDE ON CONSTRUCTION DRAWINGS)  
1. SEE SHEET 4.

**KEYED NOTES:**

- ① CONNECT SENSING LINE TO A STRAIGHT SECTION OF PIPING, MINIMUM 10 PIPE DIAMETERS OR 24\"
- ② PROVIDE 1/2\"
- ③ 3/4\"
- ④ FIRST SHUTOFF VALVE INSIDE BUILDING.
- ⑤ ON STEAM SERVICES, PROTECT THE PRESSURE GAUGE WITH A PIGTAIL SIPHON.

DRAWING DEVELOPED FOR ML-3/ML-4 PROJECTS. FOR ML-1/ML-2, ADDITIONAL REQUIREMENTS AND QA REVIEWS ARE REQUIRED. (REMOVE THIS NOTE WHEN INSERTED INTO A DRAWING PACK-AGE).

1	8-13-03	U	REVISED DETAIL. DWG NO. WAS ST6202.	RP	RF	JM	GG	TO
NO	DATE	CLASS	REV	DESCRIPTION	DWN	DSGN	CHKD	SUB/APP
<p><b>FACILITY &amp; WASTE OPERATIONS</b> <b>DESIGN ENGINEERING CONSTRUCTION SERVICES</b></p>								
<p><b>ENGINEERING STANDARDS MANUAL</b></p>				<p>DRAWN: R. PEARSON</p>				
<p>STEAM PRV STATION DETAIL PARALLEL</p>				<p>DESIGN: R. FROST</p>				
<p>BLDG X</p>				<p>TA-X</p>				
<p>SUBMITTED</p>				<p>APPROVED FOR RELEASE</p>				
<p>DISCIPLINE POC: GURINDER GREWAL</p>				<p>STANDARDS MANAGER: TOBIN ORUCH</p>				
<p>CLASSIFICATION: U</p>				<p>REVIEWER: LARRY BAYS</p>				
<p>PROJECT ID</p>				<p>DRAWING NO</p>				
<p>CHAPTER 6</p>				<p>ST-D3020-2</p>				<p>REV 1</p>